# Natural Gas Generator set data sheet (01-01-2018)



Prime 132kWe, Natural Gas



Gas Generator Set Model:	TPI165XG	Gas Engine Model:	PS D08		Alternator Model:		Leroy Somer LSA 44.3 L10	
60Hz 1800 r.p.m		<b>iase</b> lires	<i>Power Factor:</i> <i>Cos ⊄</i> = 0.8		Emissions Standard		N/A	
	Prime Power		Continuous Power		Rated Current	Thermal Output	Efficiency	
RATINGS <sup>2 )</sup>	(PRP)		(COP)				Eletrical	Thermal <sup>3)</sup>
Voltage (V)	kW	kVA	kW	kVA	Amps	kW	η	(%)
380/220	132	165	N/A	N/A	250.7	156		
416/240	132	165	N/A	N/A	229.0	156	39.0%	46.0%
440/254	132	165	N/A	N/A	216.5	156		
480/277	132	165	N/A	N/A	198.5	156		

#### Conditions and Defintions:

1) COP are applicable for supplying continuous electrical power for full load operations, there is no overload available.

2) Engine output data under ISO8528/1, ISO3046/1, BS5541/1, DIN6271 conditions.

#### **Genset General Specifications**

Gas Genset model	TPI165XG	Electrical efficiency	39.0%
Gas Engine model	D081L	Thermal efficiency	46.0%
Electrical output (kW/kVA)	132/165	Total efficiency	85.0%
Fuel	Natural gas	Speed regulating rate	0-5% Adjustable
Frequency (HZ)	60	Dimension (length×width×height) (mm)	2500×950×1520
Speed (rpm)	1800	Net Weight (kg)	1550

Engine Specifications			
Manufacturer	PSI	Exhaust system	
Model	D081L	Maximum allowable Back pressure	10.2 kPa
Mechanical power	150 kWm	Exhaust flow at rated power	31.9 m3/min
Speed	1800 rpm	Maximum turbine inlet temperature	750°C
Configuration / number of cylinders	In line / 6		
Bore / Stroke	111/139 mm	Air induction system	
Displacement	8.1 L	Maximum allowable Intake Air Restriction w	rith Air Cleaner
Compression ratio	10.5:1	- Clean	1.24 kPa
Firing Order	1-5-3-6-2-4	- Dirty	3.74 kPa
Direction of rotation Counter clockwis	se from flywheel	Combustion air required (entire engine)	10 m <sup>3</sup> /min
Speed Governor	Electronic		
Ignition system	Altronic	Fuel system	
Spark plug	NGK	Maximum EPR rated pressure	6.9 kPa
Induction system Turbo ch	narge air cooled	Minimum running pressure to EPR	1.7 kPa
Combustion type	Spark ignition	Minimum gas supply pipe size	2 x 2" NPT
Cooling mode	Radiator	Lower calorific value	34.71 MJ/Nm <sup>3</sup>
		Gas consumption at 100% standby	48.0 Nm <sup>3</sup> /h
Cooling system		Gas consumption at 100% load	43.6 Nm <sup>3</sup> /h
Total coolant capacity (engine only)	22.7 Litres	Gas consumption at 75% load	32.7 Nm <sup>3/</sup> h
Total coolant capacity (engine with radiato	r) 80 Litres	Gas consumption at 50% load	21.8 Nm <sup>3/</sup> h
Engine Coolant Flow	240 Liters/min	Gas consumption at 25% load	10.9 Nm3/h
Standard Thermostat Range	71-85°C		
Maximum allowable top tank temperature	104-110 °C	Electrical system	
		Charging generator 24	V x 45A alternator
Lubrication system		Starting motor	24V x 4.5kW
Engine oil capacity (min-max)	17-24 Litres	Battery voltage	24V
Oil filter capacity	3.5 Litres		
Oil consumption	≪1.0 g/kW.h	Thermal Data	
Maximum allowable oil temperature	121°C	Heat rejected to cooling water at rated Load 9	
Oil grade API CD/CF or highe	er, SAE 15W-40	Heat rejection per CAC	13.4 kW

#### Alternator Specifications

Manufacture / Brand	Leroy-Somer	Prime output power	138kW/172kVA
Model	LSA44.3L10	Insulation class	Н
AVR model	R250	Voltage regulation	± 0,5 %
Coupling / Bearing	Direct /Single bearing	Totale Harmonic distortion THD	in no-load<2%
Phase	3 Phase	Totale Harmonic distortion THD	on linear load<5%
Power factor	$\cos \mathcal{C} = 0.8$	Wave form : NEMA = TIF - (*)	< 50
Winding pitch - code	2/3 - (wdg6)	Altitude	≤ 1000 m
Drip proof	IP 23	Overspeed	2250 min <sup>-1</sup>
Excitation	Shunt	Air flow	0.30 m³/s

60Hz/1800R.P.M

*Tide Power Technology Co., Ltd.* NO.1 Building, YiXu Mechanical & Electrical Park, Gaishan Town, Cangshan District, Fuzhou, Fujian, China. Our Tel.: 86-591-28068999, Fax.: 86-591-28068900 (www.tpshk.com - learn more)



- Deep sea DSE7320 controller
- Digital control panel
- Volts, current, frequency, rpm (instruments)
- Genset running hours
- Battery voltage and charging
- Over speed pre-alarm & shutdown
- High water temp. pre-alarm & shutdown
- Low oil pressure pre-alarm & shutdown
- Low voltage pre-alarm & shutdown
- Overcurrent pre-alarm & shutdown

#### **Standard Features**


- High efficient water cooled gas engine with radiator
- Brushless alternators (Class H, with AVR.)
- Heavy duty rubber anti-vibration mountings
- Starter batteries and connecting cables
- Separate engine-drive battery charging alternator
- Industrial silencer for open type generator sets
- Circuit breaker 3 pole (MCCB)
- Maintenance free battery
- Low coolant level sensor
- Oil filter Air filter

## Optional

- Automatic Transfer Switch (ATS)
- Canopy/Enclosure
- $\bigcirc$  Water heater for severe cold weather
- $\bigcirc$  Lub-oil heater for severe cold weather
- Silent containerised
- $\bigcirc$  Residential silencer
- $\odot$  Panel for auto synchronization with Mains
- $\bigcirc$  Extra air filters for time-maintenance
- $\bigcirc$  Automatic oil supply system

- Fully welded steel baseframe
- Ignition system
- Gas train: ball valve, gas filter, gas pressure regulator, pressure gauge,electromagnetic valve;
- Wiring with IEC standard
- Factory test certificate
- Operation & Maintenance manual & Diagrams
- Worldwide product / Technical support
- $\bigcirc$  Extra oil filters for time-maintenance
- O Parallel cabinet
- Full range of attachments and options available for alternator
- Flame arrestor in gas train
- Desulfurization system
- Gas pretreatment system
- Dehydration system
- Genset Comissioning / Testing on site

### **Combined Heat and Power Systems**



We offer Combined Cooling Heating and Power (CHP and CCHP) packages for our gas generator sets. It can recover 75%-90% combined electrical and thermal efficiency, resulting in major reductions in your overall energy costs. In the past years we have supplied CHP systems to Germany, Russia,Indonesia etc. We have the experience and capabilities to meet your total energy requirements.

#### Warranty

The goods of Tide Power Technology are under warranty against defects in materials and workmanship for period 1 year or 2000 hours operation time whichever come first from the date of delivery to the end user (except the damageable spare parts of genset caused by incorrect man-made operation), and that the aforementioned warranty for the same token is back up by the engine (8750 hours for continuous duty which should not exceed 75% of the prime power rating) & alternator manufactures and their global distributors.